Docusign Envelope ID: 8CB1D6AE-E7A9-45B4-BB03-3FBF11D72518

SGS

Tested For:	**Denis Milovidov**	**Phone:**	(786) 512-9248	**Received:**	5/20/2025
	Novatik Distribution, LLC	**Fax:**		**Completed:**	5/29/2025
	4430 Wilder Rd	**Mobile:**		**Code:**	H
	Naples, FL 34105	**PO#:**		**Test Report:**	3-59450-0
	USA	**Email:**	info@novatik.us		

Key Test: ASTM E 108 Burning Brand - Class A 4000

Client's Identification:

Style: Classic, Roman, Slate, Wood. Additional Information: 2 Layers of Vera Shield FR Underlayment.

LE: 2024; V: 01/25 BG /tm

Test Performed: ASTM E 108 – Standard Test Methods for Fire Tests of Roof Coverings – Section 1.1.3 – Burning Brand (Section 10)

Brand Size: 12" x 12" x 2-1/4" [1 brand per deck] [4 decks]

Slope of Test Deck: ☒ 5 inches per horizontal foot; ☐ Other: _____

Calibration Details: 1) Velocity Measurement: 5.1 to 5.5 m/s

2) Flame Temperature of Igniting Flame: 1630 ± 50°F

Description of Roof Covering Construction: Metal Roofing Direct to Deck

Conditioning: The completed test assemblies are stored in freely circulating air at 60°F to 90°F (16°C to 32°C) to cure the assembly components [6.3.2]

Moisture Content of Test Deck Materials at Test Time: Actual: 9.1%; Required: 8% to 12%

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

Docusign Envelope ID: 8CB1D6AE-E7A9-45B4-BB03-3FBF11D72518

SGS

Tested For:	**Denis Milovidov**	**Phone:**	(786) 512-9248	**Received:**	5/20/2025
	Novatik Distribution, LLC	**Fax:**		**Completed:**	5/29/2025
	4430 Wilder Rd	**Mobile:**		**Code:**	H
	Naples, FL 34105	**PO#:**		**Test Report:**	3-59450-0
	USA	**Email:**	info@novatik.us		

Key Test: ASTM E 108 Burning Brand - Class A 4000

Abbreviations Which May Be Used:
NT = Not tested.
EXT = Extinguished by technician when failure criteria was reached.

Results:

Test Deck #	Sustained Flaming on Underside of Deck (Yes/No) (Time hr:mm)	Production of Flaming or Glowing Brands (Yes/No)	Displacement of Portions of Test Sample (Yes/No)	Exposure or Falling Away Portions of Roof Deck (Yes/No)
1	☐ Yes ☒ No :	**No**	**No**	**No**
2	☐ Yes ☒ No :	**No**	**No**	**No**
3	☐ Yes ☒ No :	**No**	**No**	**No**
4	☐ Yes ☒ No :	**No**	**No**	**No**

Acceptance Criteria for Burning Brand Test: There shall be no:

1) Portions of the roof covering material that are blown or fall off the test deck in the form of flaming or glowing brands that continue to glow after reaching the floor.
2) Exposure of the roof deck.
3) Portions of the roof deck that fall away in the form of particles that continue to glow after reaching the floor.
4) Sustained (uninterrupted for 5 seconds or more) flaming of the underside of the deck.

Remarks: None

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

96 Allen Boulevard Suite D, Farmingdale, NY 11735 USA • Phone: (631) 293-8944 • Email: govmark.test.reports@sgs.com

Docusign Envelope ID: 8CB1D6AE-E7A9-45B4-BB03-3FBF11D72518

Tested For:	**Denis Milovidov**	**Phone:**	(786) 512-9248	**Received:**	5/20/2025
	Novatik Distribution, LLC	**Fax:**		**Completed:**	5/29/2025
	4430 Wilder Rd	**Mobile:**		**Code:**	H
	Naples, FL 34105	**PO#:**		**Test Report:**	3-59450-0
	USA	**Email:**	info@novatik.us		

Key Test: ASTM E 108 Burning Brand - Class A 4000

Conclusion: Based on the above Results and Acceptance Criteria, the item tested:

☒ Does comply with a Class A rating; ☐ Does not comply with a Class A rating

Certification: I certify that the above results were obtained after testing specimen(s) in accordance with the procedure and equipment specified above.

DocuSigned by:
Michael Magee
1D12C24670EA402...

5/30/2025

AUTHORIZED SIGNATURE
SGS North America
/jo/jb

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.