Docusign Envelope ID: 4842EF1B-280E-8E83-8233-3BD84F1BCF39

SGS

Tested For:	**Denis Milovidov**	**Phone:**	(786) 512-9248	**Received:**	5/20/2025
	Novatik Distribution, LLC	**Fax:**		**Completed:**	5/29/2025
	4430 Wilder Rd	**Mobile:**		**Code:**	H
	Naples, FL 34105	**PO#:**		**Test Report:**	3-63213-0
	USA	**Email:**	info@novatik.us		

Key Test: ASTM E 108 Class A 0

Client's Identification:

Novatik Nature - Stone Coated Steel System. Style: Classic, Roman, Slate, Wood. Additional Information: 2 Layers of Vera Shield FR Underlayment.

LE: 2025 V 05/25 /bg /tm

Test Performed: ASTM E 108-25 – Standard Test Methods for Fire Tests of Roof Coverings

Slope of Test Deck: ☒ 5 inches per horizontal foot; ☐ Other: _____

Calibration Details: 1) Velocity Measurement: 5.1 to 5.5 m/s

2) Flame Temperature Measurements: 1400 ± 50°F (760 ± 28°C)

Description of Roof Covering Construction: Metal Roofing Direct to Deck

Conditioning: The completed test assemblies are stored in freely circulating air at 60°F to 90°F (16°C to 32°C) to cure the assembly components [6.3.2]

Moisture Content of Test Deck Materials at Test Time: Actual: 9.1%; Required: 8% to 12%

Test Specimen: ☒ Built by SGS per client's instructions
☐ Built by client, received by SGS on _____
☐ Received by 3rd Party Inspection Agency _____ on _____

– See Pages 2 through 4 for Results –

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

Docusign Envelope ID: 4842EF1B-280E-8E83-8233-3BD84F1BCF39

SGS

Tested For:	**Denis Milovidov**	**Phone:**	(786) 512-9248	**Received:**	5/20/2025
	Novatik Distribution, LLC	**Fax:**		**Completed:**	5/29/2025
	4430 Wilder Rd	**Mobile:**		**Code:**	H
	Naples, FL 34105	**PO#:**		**Test Report:**	3-63213-0
	USA	**Email:**	info@novatik.us		

Key Test: ASTM E 108 Class A 0

I. Intermittent Flame Exposure Results:

Flame On: 2 min, Flame Off: 2 min, 15 Test Cycles

Test Deck #	Sustained Flaming on Underside of Deck (Yes/No) (Time hr:mm)	Flaming or Glowing Roof Coverings on the Floor (Yes/No)	Exposure of the Roof Deck (Yes/No)	Falling Away Portions of Roof Deck (Yes/No)
1	☐ Yes ☒ No N/A	No	No	No
2	☐ Yes ☒ No N/A	No	No	No

Note: N/A = Not Applicable

Acceptance Criteria for Intermittent Flame Exposure Test: There shall be no:

1) Portions of the roof covering material that are blown or fall off the test deck in the form of flaming or glowing brands that continue to glow after reaching the floor.
2) Exposure of the roof deck.
3) Portions of the roof deck that fall away in the form of particles that continue to glow after reaching the floor.
4) Sustained (uninterrupted for 5 seconds or more) flaming of the underside of the deck.

Intermittent Flame Exposure Conclusion: Based on the above Intermittent Flame Exposure Results and Acceptance Criteria, the item tested:

☒ Does comply with a Class A rating; ☐ Does not comply with a Class A rating

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

Docusign Envelope ID: 4842EF1B-280E-8E83-8233-3BD84F1BCF39

SGS

Tested For:	**Denis Milovidov**	**Phone:**	(786) 512-9248	**Received:**	5/20/2025
	Novatik Distribution, LLC	**Fax:**		**Completed:**	5/29/2025
	4430 Wilder Rd	**Mobile:**		**Code:**	H
	Naples, FL 34105	**PO#:**		**Test Report:**	3-63213-0
	USA	**Email:**	info@novatik.us		

Key Test: ASTM E 108 Class A 0

II. Spread of Flame Results:

Test Deck #	Distance of Flame Spread (ft, in)	Flaming or Glowing Roof Coverings on the Floor (Yes/No)	Significant Lateral Flame Spread (Yes/No)	Exposure of the Roof Deck (Yes/No)	Falling Away Portions of Roof Deck (Yes/No)
1	1 ft, 2.5”	No	No	No	No
2	1 ft, 2.5”	No	No	No	No

Observations During Testing: No unusual observations

Acceptance Criteria for Spread of Flame Test: There shall be no:

1) Portions of the roof covering material that are blown or fall off the test deck in the form of flaming or glowing brands that continue to glow after reaching the floor.
2) Exposure of the roof deck.
3) Portions of the roof deck that fall away in the form of particles that continue to glow after reaching the floor.
4) Flame spread beyond 6 ft (1.8 m).
5) Significant lateral spread of flame from the path directly exposed to the test flame.

Spread of Flame Conclusion: Based on the above Spread of Flame Results and Acceptance Criteria, the item tested:

☒ Does comply with a Class A rating; ☐ Does not comply with a Class A rating

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company’s findings at the time of its intervention only and within the limits of Client’s instructions, if any. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

96 Allen Boulevard Suite D, Farmingdale, NY 11735 USA • Phone: (631) 293-8944 • Email: govmark.test.reports@sgs.com

Docusign Envelope ID: 4842EF1B-280E-8E83-8233-3BD84F1BCF39

Tested For: **Denis Milovidov**
Novatik Distribution, LLC
4430 Wilder Rd
Naples, FL 34105
USA

Phone: (786) 512-9248
Fax:
Mobile:
PO#:
Email: info@novatik.us

Received: 5/20/2025
Completed: 5/29/2025
Code: H
Test Report: 3-63213-0

Key Test: ASTM E 108 Class A 0

III. Burning Brand Results:

Test Deck #	Sustained Flaming on Underside of Deck (Yes/No) (Time hr:mm)	Flaming or Glowing Roof Coverings on the Floor (Yes/No)	Exposure of the Roof Deck (Yes/No)	Falling Away Portions of Roof Deck (Yes/No)
1	☐ Yes ☒ No N/A	No	No	No
2	☐ Yes ☒ No N/A	No	No	No
3	☐ Yes ☒ No N/A	No	No	No
4	☐ Yes ☒ No N/A	No	No	No

Note: N/A = Not Applicable

Observations During Testing: No unusual observations

Acceptance Criteria for Burning Brand Test: There shall be no:

1) Portions of the roof covering material that are blown or fall off the test deck in the form of flaming or glowing brands that continue to glow after reaching the floor.
2) Exposure of the roof deck.
3) Portions of the roof deck that fall away in the form of particles that continue to glow after reaching the floor.
4) Sustained (uninterrupted for 5 seconds or more) flaming of the underside of the deck.

Burning Brand Conclusion: Based on the above Burning Brand Results and Acceptance Criteria, the item tested:

☒ Does comply with a Class A rating; ☐ Does not comply with a Class A rating

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.

Docusign Envelope ID: 4842EF1B-280E-8E83-8233-3BD84F1BCF39

Tested For:	**Denis Milovidov**	**Phone:**	(786) 512-9248	**Received:**	5/20/2025
	Novatik Distribution, LLC	**Fax:**		**Completed:**	5/29/2025
	4430 Wilder Rd	**Mobile:**		**Code:**	H
	Naples, FL 34105	**PO#:**		**Test Report:**	3-63213-0
	USA	**Email:**	info@novatik.us		

Key Test: ASTM E 108 Class A 0

Product Classification Analysis: Based on the Results from Intermittent Flame Exposure, Spread of Flame, and Burning Brand Tests, the product tested:

☒ Achieves a rating of Class A; ☐ Does not achieve a rating of Class A

Certification: I certify that the above Results were obtained after testing specimen(s) in accordance with the procedures and equipment specified above.

DocuSigned by:
Michael Magee
1D12C24670FA402...

7/14/2026

AUTHORIZED SIGNATURE
SGS North America
/tm

The results contained in this report relate only to the item(s) tested. The test report shall not be reproduced except in full, without written approval from SGS North America.

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/terms-e-document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for a maximum of 45 days only.