

TEST RESULTS SUMMARY

REPORT FOR: XYZ Sprinkler Company
2357 VENTURA DR
STE 108
SAINT PAUL MN 55125

PO: Example PO
Job: Example Report

Job Number: 17041
Date Received: 12/18/2024
Report Date: 12/22/2024
Page: 1 of 1

Sample Numb	Tank ID	Product	Sampling Point	Tank Type	Pass/Fail
1	1	Ansulite® 3/6% AR-AFFF A364	Bottom	Bladder Tank	Pass

It is the responsibility of the property owner or designated representative to ensure the sample information is correct and to correct deficiencies or impairments, including identifying and replacing any recalled products. The results relate only to the sample tested using a limited number of laboratory-scale methods and do not guarantee the system will operate properly. This report shall not be reproduced except in full without the written consent of Dyne Fire Protection Labs, LLC.



FIRE PROTECTION LABS
dyne

2357 Ventura Dr Suite 108
Woodbury MN 55125
(800)632-2304
lab@dyneusa.com