

Laboratory Test Summary

A sample of: Mfg: Not Specified
Pdt: Dry Chemical

From system: 1

Located at: Example Report

Was tested on: 9/27/2021

To fulfill: IMO MSC.1/Circ. 1432, dated 31/5/2012,
section 8.2.4

PASS

Next test: IMO 1432 requires a sample of dry
chemical powder be tested for moisture
content every 2 years.

FOR SERVICE ON THIS TANK CONTACT:

XYZ Sprinkler Company

2357 VENTURA DR

STE 108

SAINT PAUL, MN 55125

(800) 000-0000

jennie@dyneusa.com

Dyne Job: 45496 Sample: 1

The results relate only to
the sample tested and do
not guarantee the system
will operate properly.

