

VOICE ALARM LABEL



Product Features

- British Standard compliant
- Vinyl based adhesive label for durability
- Clear font with contrast background for improved legibility

Non-Domestic Fire Alarms	Grade C Fire Alarms	Grade D Fire Alarms	Emergency Lighting	Voice Alarms	Emergency Voice Communications	Evacuation Alert Systems
						

Product Description

This Voice Alarm system label has been designed to satisfy the requirements of the British Standards as described below:

BS 5839-8:2023 Clause 16.3 states...

The ANS sensor should be clearly labelled "VOICE ALARM".

BS 5839-8:2023 Clause 25.1.6a states...

Every isolator and protective device that can isolate the supply to the voice alarm system, other than the main isolator for the building, should be labelled "VOICE ALARM".

BS 5839-8:2023 Clause 26.12 states...

Where practicable, cables should be installed without external joints and enclosed in junction boxes labelled "VOICE ALARM".

Product Specification	
Product Code	FD-LAB-VA
Labels per Pack	24
Label Size	20mm x 70mm
Label Material	Vinyl