

Confirmation

LEED

On 31 January 2014, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

UZIN MK 200

supplied by

Uzin Utz AG

The sample was supplied as being representative of the manufactured product, and it has been tested as wood flooring adhesive in accordance with the relevant ISO 16000, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2014-00018601_EN and 392-2014-00018701).

The test results of the tested adhesive indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and/or VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

VOC contents were below the limit value specified as 100 g/l VOC minus water per liters for wood flooring adhesives.

Actual VOC content of the product was below 55 g/l VOC minus water.

15 October 2015



Thomas Bjerring
Analytical Service Manager



Janne R. Norup
Chemist