

195579

PART B - APPLIANCE RECORD AND REMEDIAL WORK SHEET

Registered Business/engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500



TICK BOXES AS APPROPRIATE

Type	Appliances	Make	Model	Serial Number (if required)	Manufacturer's instructions available	Operating pressure (inbar) and/or heat input (kW)	FSD fitted to all burners	All appliances safety devices (including FSDs) operating correctly	Adequate ventilation arrangements	Adequate flueing/extract or isolation valve arrangement	Appliance Gas plug and socket fitted	Movable appliances fitted with appropriate gas hose with restraint fitted correctly	Appliance pipework gas tight	Appliance safe to use
1.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
2.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
3.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
4.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
5.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
6.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
7.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
8.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
9.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
10.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
11.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
12.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
13.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
14.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐
15.	PATIA	Garcon	700	41295105	Yes ☒ No ☐	37	Yes ☐ No ☒	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☐ No ☒ N/A ☐	Yes ☒ No ☐ N/A ☐	Yes ☒ No ☐ N/A ☐

Additional works deemed necessary/recommended

Essential ☐ Recommended ☐

Essential ☐ Recommended ☐

Essential ☐ Recommended ☐

Essential ☐ Recommended ☐

Other comments

Overall Risk Analysis of kitchen ventilation and where provided, flue/chimney, or extract systems

Has risk assessment in accordance with IGEW/JP/19 been applied

This inspection Record confirms the adequacy or otherwise of the commercial catering gas installation at the establishment detailed at the address on Part A of this record.

Gas Safe Registered Engineer's signature: Date: 16/04/2026