5. Declaration Of Conformity With The Atex Directive 2014/34/EU & UK Directive SI 2016 No. 1107 (as amended)

Raytec Ltd. declares under our sole responsibility that the product(s) listed below conform with the relevant provisions of directive 2014/34/EU of 20th April 2016 and UK Directive SI 2016 No. 1107 (as amended)

Manufacturer	Raytec Ltd Unit 15, Wansbeck Business Park Rotary Parkway Ashington Northumberland NE63 8QW United Kingdom
Description of Equipment	Spartan range of linear luminaires – standard and emergency
Certification Body	CML New Port Road Ellesmere Port CH65 4LZ
Certificate numbers	CML14ATEX3119 & IECExCML15.0001 & CML21UKEX3105 CML15ATEX4138 & IEC Ex CML15.0068 & CML21UKEX4104 CML16ATEX1130 & IEC Ex CML16.0052 & CML21UKEX1100 ATEX Quality Assurance Notification CSA BV (2813) UKCA Quality Assurance Notification CSA UK (0518)

CML14ATEX3119 or IEC Ex CML15.0001 or CML21UKEX3105

Standard variants	Emergency variants
II 2 GD Ex eb mb IIC T4 Gb	II 2 GD Ex eb mb IIC T4 Gb
Ex tb IIIC T80°C Db	Ex tb IIIC T76°C Db
-40°C to +60°C	-20°C to +50°C

CML15ATEX4138 or IEC Ex CML15.0068 or CML21UKEX4104

Standard variants	Emergency variants
II 3 GD Ex ec mc IIC T4 Gc	II 3 GD Ex ec mc IIC T4 Gc
Ex tc IIIC T80°C Dc	Ex tc IIIC T75°C Dc
-40°C to +60°C	-20°C to +50°C

UK / Europe Tel: +44 (0) 1670 520055
Americas Tel: +1 613 270 9990

CML16ATEX1130 or IEC Ex CML16.0052 or CML21UKEX1100

Standard variants	Emergency variants
II 2 D Ex tb IIIC T80°C Db	II 2 D Ex tb IIIC T76°C Db
-40°C to +60°C	-20°C to +50°C

IP66 & IP67
110V-254V AC or 18-48V AC/18-69V DC

Compliance with the Essential Health and Safety Requirements has been assessed by reference to the following standards -

EN 60079-0 : 2018	EN 60079-31 : 2014
EN 60079-7: 2015+A1:2018	EN 60079-18:2015+A1:2017

And also 2014/35/EU – Low Voltage Directive, 2014/30/EU – EMC Directive

Signed 

Name Jonathan Sommersett
Position Technical Director

Dated

Serial number