

Certification Record

Listing#: E115626
Report #: NRTL 15892A
Original Certification Date: August 04, 2023
Revised Certification Date:

This Certification is issued to:

Raytec Ltd.
Unit 15 Wansbeck Business Park,
Rotary Parkway,
Ashington Northumberland,
NE63 8QW,
United Kingdom

Stating that the product(s):

SPARTAN LED Linear Luminaire, Model SPZ-WL Series, model references:

SPZ-WL84-CID2
SPZ-WL168-CID2
SPZ-WLXX-HO--xy –CID2 Series
SPZ-WLXX-EMXab-CID2 Series

Achieved Certification to the following standard(s):

CSA C22.2 No. 94.2-07
CSA C22.2 No. 25-1996
CSA C22.2 No. 213-M1987
CSA C22.2 No. 250.13-14
CSA C22.2 No. 141-15
UL 50E 1st edition
ANS/ISA-12.12.01-2013
UL 8750 1st edition
UL 1203 5th edition
UL 844 13th edition
UL 924 10th edition



Rating:

Model #	SPZ-WL84-CID2	SPZ-WL168-CID2	Emergency		WL84-HO	WL168-HO	WL84-HO-EM/ WL84-HO-EMX
Input Voltage	110-254 Vac(-HV) or 18-		110-254 Vac		110-254	110-254 Vac	110-254 Vac
Mains frequency	50/60 Hz						
No. of LED's	84	168	84	168	84	168	84
Max. power	34 W	68 W	34W	68W	46W	92W	60W
Ingress protection	Enclosure Type 4X						

Class I, Div. 2 Gr ABCD T4/T5/T6

Class II, Div. 1, Div. 2 Gr EFG T4/T5/T6

Tamb = -40°C ≤ Tamb ≤ +45°C or +55°C

Enclosure Type 4X

Eurofins MET Labs Safety Laboratory

All changes proposed in the previously identified product that affects the above information must be submitted to Eurofins MET Labs for evaluation prior to implementation to assure continued MET Certification status.

The covered product(s) shall be subject to follow-up inspections to ensure that the Certified product(s) are identical to the product sample evaluated by Eurofins MET Labs and that all manufacturer's responsibilities are being fulfilled as specified in the Manufacturer's Responsibility section of the Certification report. The applicant named above has been authorized by Eurofins MET Labs to represent the product(s) listed in this record as "MET Certified" and to mark this/these product(s) according to the terms and conditions of the MET Applicant Contract, MET Listing Reports, and the applicable marking agreements. Only the product(s) bearing the MET Mark and under a follow-up service are considered to be included in the MET Certification program. This certification has been granted under a System 3 program as defined in ISO/IEC 17067.



Eurofins MET Labs is accredited by OSHA and the Standards Council of Canada.
Eurofins MET Labs – The Nation's First Nationally Recognized Testing Laboratory

NRTL