

TECHNICAL ARTICLE

Passive vs. active ground monitoring

For years now simple passive grounding has been used throughout industry as a low-cost safety measure and protection against fires and explosions caused by static electricity but is it as safe as you think?



Intrinsically safe, heavy duty, dual core static grounding clamp

Passive grounding clamps

Passive grounding clamps and cables are only suitable if the metallic object to be grounded has a bright clean surface. This allows even a poorly designed passive grounding clamp to make a low resistance connection to the metal object.



An example of a passive grounding clamp

However, not every industrial environment can use a bright clean metal surface, as mild steel usually needs painting to prevent rust and corrosion. This is clearly a physical barrier between the metal surface and the passive grounding clamp.

Paint is the number one enemy of successful and reliable passive grounding. The other main enemy is the product itself causing a barrier between the metal and the clamp with passive grounding, even bright clean stainless steel can be affected by product coatings.

Active grounding clamps

So, what is the alternative to passive grounding clamps and cables? Well, it is active grounding clamps and cables. When you use passive grounding clamps how do you know that you have made a good low resistance connection to the metal object and the local site ground point? You do not, you just cross your fingers!



Active grounding with the Bond-Rite® CLAMP

Active grounding clamps contain intrinsically safe circuits that measure the resistance from between its teeth and the local site ground point to be 10 ohms or less. This metal to metal 10 ohms or less resistance level is enshrined in International Standards (**IEC TS 60079-32-1**), **Guidance (NFPA 77)** and **Recommended Practices (API RP 2003)**.

This 10 ohms or less connection with an active grounding clamp is confirmed to the user by a high intensity flashing green LED. So use of active grounding clamps and cables, takes the guesswork out of safety, allowing you to uncross your fingers and most importantly be safe.

What are the differences between passive and active grounding clamps and cables?

Passive monitoring clamp and cables

- A metallic earthing clamp designed to provide a resistance of 10 ohms or less.

- If there is a 'break' in the connection or the resistance to earth rises above 10 ohms, there is no way of knowing during the operation.
- Unable to confirm a good earth connection before the process begins.

Active monitoring clamp and cables

- Provides a resistance of 10 ohms or less as indicated via a high intensity flashing green LED within the system enclosure or on the **Bond-Rite® Clamp**.
- The Green (GO) indication aids the SOP, e.g. do not proceed until the LED has gone green.
- Operators and plant personnel are accountable and secure about their working environment. Provides confidence that the process is reliably earthed before the operation commences.
- Performance is continuously monitored throughout the duration of the operation.

Copyright Notice

The document and its content is copyright of Newson Gale Ltd © 2024. All rights reserved.

Any redistribution or reproduction of part or all of the contents in any form is prohibited other than the following:

- You may print or download to a local hard disk extracts for your personal and non-commercial use only
- You may copy the content to individual third parties for their personal use, but only if you acknowledge the website as the source of the material

You may not, except with our express written permission, distribute or commercially exploit the content. Nor may you transmit it or store it in any website or other form of electronic retrieval system.

Right to change

This document provides general information only and may be subject to change at any time without notice. All information, representations, links or other messages may be changed by Newson Gale at any time without prior notice or explanation.

Newson Gale is not obliged to remove any outdated information from its content or to expressly mark it as being outdated. Please seek the advice of professionals as necessary regarding the evaluation of any content.

Disclaimer of liability

The information provided in this document is provided by Newson Gale without any representations or warranties, expressed or implied, as to its accuracy or completeness. The liability of Newson Gale for any expenses, losses or actions incurred whatsoever by the recipient as a result of the use of this document shall be excluded.

United Kingdom

Newson Gale Ltd
Omega House, Private Road 8
Colwick, Nottingham
NG4 2JX, UK
+44 (0)115 940 7500
groundit@newson-gale.co.uk

United States

IEP Technologies LLC
417-1 South Street
Marlborough, MA 01752
USA
+1 732 961 7610
groundit@newson-gale.com

Germany

IEP Technologies GmbH
Kaiserswerther Str. 85C
40878 Ratingen
Germany
+49 (0)2102 5889 0
erdung@newson-gale.de